

Parkes Sewage Treatment Plant

EPA Licence Number 5655

Parkes Shire Council
Parkes Sewage Treatment Plant
Akuna Road
PARKES NSW 2870

Location of Monitoring Point 5: Post UV pit - Sewage Treatment Plant, Akuna Road
Monitoring frequency required by licence: monthly during discharge

Date sample taken	22/ 10/ 2025
Date sample sent to laboratory	22/ 10/ 2025
Date data received from Laboratory	31/ 10/ 2025
Date data published	5/11/2025
Data published within 14 working days	YES

Pollutant (unit of measure)	Limit	Result	Limit Exceeded
Oil and Grease (mg/L)	10	<5	NO
pH	6.5 - 8.5	7.8	NO
Total Nitrogen (mg/L)	15	2.92	NO
Total Phosphorus (mg/L)	1	0.222	NO
Total Suspended Solids (mg/L)	30	2	NO
Biochemical Oxygen Demand (mg/L)	15	<2	NO
Nitrogen (ammonia) (mg/L)	5	1.03	NO
Faecal Coliforms (colony forming units per 100mL)	600	~1300	YES